

SELENA FM S.A.
Strzegomska 2-4
53-611 Wrocław
POLAND

Eurofins Product Testing A/S
Smedeskovvej 38
8464 Galten
Denmark

VOC@eurofins.com
www.eurofins.com/VOC-testing


VOC TEST REPORT Indoor Air Comfort®

16 February 2016


1 Sample Information

Sample name	NoEM ELECTRO PROTECTOR
Batch no.	16667
Production date	06.10.2015
Product type	Primer
Sample reception	17/12/2015

2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation		Regulation of March and April 2011 (DEVL1101903D and DEVL1104875A)
French CMR components	Pass	Regulation of March and April 2011 (DEVL1101903D and DEVL1104875A)
AgBB	Fail	AgBB of February 2015. DIBt of October 2010
Belgian Regulation	Pass	Royal decree of May 2015 (C-2014/24239)
Indoor Air Comfort®	Fail	Indoor Air Comfort 5.3a of March 2015
EN 717-1 [§]	E1	2004
BREEAM International	Compliant	GN22: BREEAM Recognised Schemes for VOC Emissions from Building Products

Full details based on the testing and direct comparison with limit values is available in the following pages


Janne R. Norup
Chemist


Thomas Bjerring
Analytical Service Manager